

Location	Lead Level ug/L
Ground Floor Custodial Room sink	0.4
Ground Floor Annex water fountain outside Room N3	0.72
	0.76
1st Floor Hallway water fountain outside Main Office	0.93
2nd Floor Hallway water fountain outside Room 211	1.5
1st Floor Annex Hallway water fountain #2 across from Main Gym	1.7
1st Floor Nurses Office Sink	2.2
Ground Floor Hallway water fountain across from Room 8	2.3
Room 110 sink #1	2.4
Room 211 Sink	3.4
Ground Floor Kitchen sink	3.6
	5
1st Floor Annex Boys Locker Room sink #4	5.8
1st Floor Annex Boys Locker Room sink #3	6.4
1st Floor Annex Boys Locker Room sink #2	6.8
Room 110 sink #2	7
Ground Floor Kitchen food prep sink	8.6
1st Floor Annex Hallway water fountain #1 across from Main Gym	8.7
Ground Floor Room 10 sink	9.9
1st Floor Annex Boys Locker Room sink #1	11
1st Floor Hallway water fountain across from Room 108	14.6
Room 210 Sink	46.5
Room 210 Sink	87.7
Second Floor Annex Hallway water fountain outside Room N8	NO SAMPLE
Room 210 Sink	NO SAMPLE
Room 210 Sink	NO SAMPLE
Room 210 Sink	NO SAMPLE
Room 210 Sink	NO SAMPLE
Room 210 Sink	NO SAMPLE
2nd Floor Hallway water fountain outside Girls Bathroom	NO SAMPLE
1st Floor Hallway water fountain outside Nurses Office	NO SAMPLE
Ground Floor Hallway water fountain across from Gym	NO SAMPLE
Ground Floor Room 6 sink	NO SAMPLE