

Howe School (Elmer Avenue Location)	Lead Level ug/L
1st Floor Nurses Office sink	1
Basement Kitchen Food Prep sink	1
3rd Floor Hallway water fountain next to back stairwell	1.2
Basement Room G7 sink with water fountain (new wing)	1.5
Basement Hallway water fountain outside Gym	2.2
Basement sink at Kitchen entrance #1	2.7
Basement Room G6 sink with water fountain (new wing)	3
Basement sink at Kitchen entrance #2	3.1
1st Floor Nurses Office bathroom sink	3.5
3rd Floor Room 304 sink	3.8
1st Floor Room 107 sink with water fountain (new wing)	3.8
1st Floor Hallway water fountain outside Room 112 (new wing)	4.3
2nd Floor Hallway water fountain at entrance door	4.8
1st Floor Room 110 sink with water fountain (new wing)	4.9
1st Floor Computer Room sink	5.2
1st Floor Hallway water fountain near stairs to 2nd Floor	5.4
1st Floor Room 105 sink	5.8
1st Floor Room next to Nurses Office sink	5.9
1st Floor Room 111 sink with water fountain (new wing)	6.7
Basement Room G8 sink with water fountain (new wing)	7
1st Floor Room 108 sink with water fountain (new wing)	8.1
1st Floor Room 109 sink with water fountain (new wing)	8.3
1st Floor Room 104 sink with water fountain	12
1st Floor Hallway water fountain near steps	No Result Lab