

Keane Elementary School**Lead Level ug/L**

Basement Faculty Room sink	1.5
2nd Floor Hallway water fountain outside Girls Bathroom	1.6
1st Floor Nurses Office sink	1.8
1st Floor Hallway water fountain outside Girls Bathroom	1.9
1st Floor Kitchen Food Prep sink #1	2
1st Floor Kitchen Food Prep sink #2	2
1st Floor Room 104 sink with water fountain	3.5
1st Floor Room 106 sink with water fountain	3.8
2nd Floor Hallway water fountain outside Boys Bathroom	4.4
1st Floor Room 102 sink with water fountain	5.3
1st Floor Annex Kitchen sink	5.6
1st Floor Lobby water fountain outside Gym	8.3
1st Floor Hallway water fountain outside Boys Bathroom	No Sample