

Oneida Middle School**Lead Level ug/L**

2nd Floor Room 227 sink #2	0.11
2nd Floor Room 227 sink #1	0.17
2nd Floor Room 231 sink	0.25
Basement Room B15 sink	0.29
2nd Floor Room 229 sink #1	0.3
Ground Floor Nurses Office sink #2	0.31
2nd Floor Room 229 sink #2	0.33
Ground Floor Room G23 sink	0.36
Basement Girls Locker Room sink #1	0.37
Ground Floor Nurses Office sink #3	0.43
Basement Boys Locker Room sink #1	0.53
Ground Floor Room G21 sink	0.54
Basement Room B12 sink	0.74
Basement Boys Locker Room sink #2	0.79
Basement Girls Locker Room sink #2	0.8
Ground Floor Room G19 sink	0.82
Ground Floor Nurses Office sink #1	0.94
Ground Floor Nurses Office sink #4	1.1
	1.8
	2.8
	3.9
Ground Floor Room G20 sink #2	4.2
2nd Floor Room 239 sink #2	4.4
Ground Floor Room G35 sink #1	4.8
Basement Room B17 sink	5.4
2nd Floor Room 251 sink #2	5.6
Ground Floor Room G31 sink #1	5.8
Ground Floor Room G09 sink #2	5.9
1st Floor Room 143 sink #3	6
Ground Floor Room G20 sink #1	6
2nd Floor Room 251 sink #4	6.6
2nd Floor Room 239 sink #1	7
1st Floor Room 113 sink #2	7.1
Ground Floor Room G13 sink #2	7.4

Ground Floor Room G35 sink #2	7.5
Ground Floor Room G09 sink #1	7.7
Ground Floor Room G13 sink #1	7.9
Ground Floor Room G31 sink #2	7.9
2nd Floor Room 251 sink #1	8.8
2nd Floor Room 241 sink #1	8.9
2nd Floor Room 241 sink #2	9.3
1st Floor Room 143 sink #1	9.5
1st Floor Room 143 sink #2	9.8
1st Floor Room 143 sink #4	9.9
2nd Floor Room 251 sink #3	11.8
1st Floor Room 113 sink #1	12
2nd Floor Room 213 sink #1	14.2
2nd Floor Room 213 sink #2	14.6
2nd Floor Room 251 sink #5	No Sample
2nd Floor Room 251 sink #6	No Sample
2nd Floor Hallway water fountain outside Room 258	No Sample
Ground Floor Room G26 prep sink	No Sample
2nd Floor Hallway water fountain outside Bathroom T215	None Detected
2nd Floor Hallway water fountain outside Bathroom T249	None Detected
1st Floor Hallway water fountain outside Bathroom T115	None Detected
1st Floor Hallway water fountain outside Bathroom T141	None Detected
1st Floor Hallway water fountain outside Room 104	None Detected
Ground Floor Hallway water fountain outside Room G15	None Detected
Ground Floor Hallway water fountain outside Room G26 #1	None Detected
Ground Floor Hallway water fountain outside Room G26 #2	None Detected
Ground Floor Hallway water fountain outside Room G29	None Detected
Ground Floor Hallway water fountain outside Room G37	None Detected
Basement Hallway water fountain outside Room B11 #1	None Detected
Basement Hallway water fountain outside Room B11 #2	None Detected