

**Pleasant Valley Elementary School****Lead Level ug/L**

	<b>Lead Level ug/L</b>
1st Floor Room 10 Sink	1.2
3rd Floor Water Fountain outside Room 206	1.3
2nd Floor Water Fountain outside Room 106	1.4
1st Floor Room 16 Sink	2.6
1st Floor Room 14 Water Fountain	3.3
2nd Floor Water Fountain outside Room 116	5.1
3rd Floor Water Fountain outside Room 216	9
1st Floor Water Fountain across from Main Office	RETESTING
2nd Floor Faculty Room Sink	< 1.0
1st Floor Kitchen Food Prep Sink	< 1.0
1st Floor Room 14 Sink	< 1.0
1st Floor Nurses Office Sink	< 1.0
1st Floor Nurses Office Bathroom Sink	< 1.0
1st Floor Room 1 Sink	< 1.0
1st Floor Room 002 Water Fountain	< 1.0
1st Floor Room 15 Sink	No Sample

\*\*This source is being retested due to a huge variance in the results of two samples form this same source.