

Location	Lead Level ug/L
3rd Floor Library Office sink	6.3
3rd Floor Library Bathroom Room 301J sink	5.3
3rd Floor Hallway water fountain outside Room 307	<0.10
2nd Floor Room 267 sink #1	38.4
2nd Floor Room 267 sink #2	46.9
2nd Floor Room 265 sink #1	23.0
2nd Floor Room 265 sink #2	11.9
2nd Floor Hallway water fountain across from Room 207	<0.10
2nd Floor Room 206 sink #1	12.4
2nd Floor Room 206 sink #2	9.4
2nd Floor Room 246 sink #1	18.2
2nd Floor Room 246 sink #2	15.8
2nd Floor Hallway water fountain outside Room 245	<0.10
2nd Floor Hallway water fountain across from Girls Gym	1.5
2nd Floor Girls Gym Office sink	166
2nd Floor Room 222 sink #1	101
2nd Floor Room 222 sink #2	337
2nd Floor Room 222 sink #3	73.4
2nd Floor Room 222 sink #4	63.5
2nd Floor Room 222 sink #5	69.8
2nd Floor Room 220 sink #1	34.3
2nd Floor Room 220 sink #2	64.6
2nd Floor Room 220 sink #3	65.9
2nd Floor Room 220 sink #4	16.7
2nd Floor Room 220 sink #5	14.8
2nd Floor Room 230 sink #1	49.6
2nd Floor Room 230 sink #2	93.5
2nd Floor Room 230 sink #3	13.8
2nd Floor Room 230 sink #4	37.8
2nd Floor Hallway water fountain across from Cafeteria	1.0
2nd Floor Cafeteria water fountain	NO SAMPLE
2nd Floor Cafeteria Kitchen sink #1	9.4
2nd Floor Cafeteria Kitchen sink #2	22.8
2nd Floor Cafeteria Kitchen sink #3	3.8

1st Floor Hallway water fountain across from Room 129	2.0
1st Floor Room 129 sink	NO SAMPLE
1st Floor Room 123 sink #1	NO SAMPLE
1st Floor Room 123 sink #2	NO SAMPLE
1st Floor Room 123 sink #3	NO SAMPLE
1st Floor Room 123 sink #4	NO SAMPLE
1st Floor Room 123 sink #5	NO SAMPLE
1st Floor Room 122 sink	NO SAMPLE
1st Floor Room 128 sink #1	NO SAMPLE
1st Floor Room 128 sink #2	10.9
1st Floor Room 128 sink #3	20.6
1st Floor Room 128 sink #4	25.1
1st Floor Room 128 sink #5	26.5
1st Floor Custodial Office sink	1.7
1st Floor Hallway water fountain next to Room 117	2.4
1st Floor Hallway water fountain next to Room 129L	1.1
1st Floor Main Gym Ice Machine in closet	NO SAMPLE
1st Floor Main Gym water fountain next to Boys Locker Room	0.18
1st Floor Room 116 sink #1	7.4
1st Floor Room 116 sink #2	11.0
1st Floor Room 114 sink #1	5.8
1st Floor Room 114 sink #2	3.7
1st Floor Room 165 sink #1	11.7
1st Floor Room 165 sink #2	20.1
1st Floor Room 167 sink #1	17.9
1st Floor Room 167 sink #2	13.0
1st Floor Hallway water fountain next to Room 106	<0.10
1st Floor Hometown Health Center Suite 109 sink #1	3.5
1st Floor Hometown Health Center Suite 109 sink #2	5.5
1st Floor Hometown Health Center Suite 109 sink #3	5.0
1st Floor Hometown Health Center Suite 109 sink #4	3.1
1st Floor Hometown Health Center Suite 109 sink #5	3.5
1st Floor Nurses Office sink #1	13.8
1st Floor Nurses Office sink #2	3.5
1st Floor Nurses Office sink #3	NO SAMPLE

1st Floor Nurses Office Bathroom sink	1.1
1st Floor Hallway water fountain outside Main Office	0.25
1st Floor Room 146 sink	14.7
1st Floor Room 180 sink	9.4
1st Floor Room 183 sink	<0.10
1st Floor Hallway water fountain outside Office of C & Inst.	1.6
1st Floor O & M shop sink with water fountain	0.68